

Number	18-002424-PR01 (NW-K20-06-en-01)
Owner	profine GmbH International Profile Group Zweibrücker Straße 200 66954 Pirmasens Germany
Product	Plastic profile, profile combination: casement member - frame member
Designation	System: KBE70 / KÖMMERLING 70 / TROCAL 70
Details	Material Polyvinyl Chloride unplasticized (PVC-U); Projected width 112 mm; Structural depth 70 mm; Casement member: Designation 3956; Cross section (W x T) 77 mm x 70 mm; Thickness of infill 24 mm; Edge cover of infill 17 mm; Reinforcement material Metals - Steel galvanized; Frame member: Designation 3906; Cross section (W x T) 63 mm x 70 mm; Reinforcement material Metals - Steel galvanized
Special features	

## Result

Thermal transmittance according to EN 12412-2:2003-07



$$U_f = 1,3 \text{ W/(m}^2\text{K)}$$


## Basis \*)

EN 12412-2:2003-07

\*) and corresponding national versions  
e.g. DIN EN)

Test report: 18-002424-PR01 PB-K20-06-de-01

## Representation



## Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

## Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

## Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

14.01.2019



Konrad Huber, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Physics



Stefan Junker, Dipl.-Ing. (FH)  
Operating Testing Officer  
Building Physics

## Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: DCD-031AF